



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Project Description

School Lead Testing

For:

Lisa Knewasser

Broome-Tioga BOCES

435 Glenwood RD

Binghamton, NY 13905

Project Manager

Joseph Palanza

Monday, August 14, 2023

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc., Pittston Division. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

428 Route 315 | Pittston, PA 18640 | 570-348-0775 p | www.microbac.com



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

*Revised Report:
Amended - See Case
Narrative.*

Broome-Tioga BOCES

Lisa Knewasser
435 Glenwood RD
Binghamton, NY 13905

Project Name: School Lead Testing

Project / PO Number: BTB-EC
Received: 04/07/2023
Reported: 08/14/2023

Case Narrative

Revision 1 - 08/14/2023: Revised to show correct MDL

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
BTB-EC-Near 520-F	T3D1085-01	Drinking Water	Grab		04/05/23 17:55	04/07/23 16:36
BTB-EC-101-WD	T3D1085-02	Drinking Water	Grab		04/05/23 18:01	04/07/23 16:36
BTB-EC-Stu.Kitch-Veggie Sink	T3D1085-03	Drinking Water	Grab		04/05/23 18:05	04/07/23 16:36
BTB-EC-Stu.Kitch-35-5	T3D1085-04	Drinking Water	Grab		04/05/23 18:05	04/07/23 16:36
BTB-EC-Stu.Kitch-Ice	T3D1085-05	Drinking Water	Grab		04/05/23 18:05	04/07/23 16:36
BTB-EC-Bistro-S	T3D1085-06	Drinking Water	Grab		04/05/23 18:08	04/07/23 16:36
BTB-EC-Bistro-Ice	T3D1085-07	Drinking Water	Grab		04/05/23 18:08	04/07/23 16:36
BTB-EC-535-3S-SL	T3D1085-08	Drinking Water	Grab		04/05/23 17:58	04/07/23 16:36
BTB-EC-535-3S-SR	T3D1085-09	Drinking Water	Grab		04/05/23 17:58	04/07/23 16:36
BTB-EC-403-F	T3D1085-10	Drinking Water	Grab		04/05/23 18:15	04/07/23 16:36
BTB-EC-403-BF	T3D1085-11	Drinking Water	Grab		04/05/23 18:16	04/07/23 16:36
BTB-EC-419-FL	T3D1085-12	Drinking Water	Grab		04/05/23 18:17	04/07/23 16:36
BTB-EC-419-BF	T3D1085-13	Drinking Water	Grab		04/05/23 18:18	04/07/23 16:36
BTB-EC-419-FR	T3D1085-14	Drinking Water	Grab		04/05/23 18:18	04/07/23 16:36
BTB-EC-434-S	T3D1085-15	Drinking Water	Grab		04/05/23 18:19	04/07/23 16:36
BTB-EC-405-WD	T3D1085-16	Drinking Water	Grab		04/05/23 18:20	04/07/23 16:36
BTB-EC-306-S	T3D1085-17	Drinking Water	Grab		04/05/23 18:29	04/07/23 16:36
BTB-EC-306-WD	T3D1085-18	Drinking Water	Grab		04/05/23 18:29	04/07/23 16:36
BTB-EC-Garden Cafe-S	T3D1085-19	Drinking Water	Grab		04/05/23 18:32	04/07/23 16:36
BTB-EC-Garden Cafe-WD	T3D1085-20	Drinking Water	Grab		04/05/23 18:24	04/07/23 16:36
BTB-EC-329-S	T3D1085-21	Drinking Water	Grab		04/05/23 18:27	04/07/23 16:36
BTB-EC-Hall by 113-WD	T3D1085-22	Drinking Water	Grab		04/05/23 18:57	04/07/23 16:36
BTB-EC-Hall by 136-S	T3D1085-23	Drinking Water	Grab		04/05/23 18:45	04/07/23 16:36
BTB-EC-X from 130-FL	T3D1085-24	Drinking Water	Grab		04/05/23 18:34	04/07/23 16:36
BTB-EC-X from 130-FR	T3D1085-25	Drinking Water	Grab		04/05/23 18:35	04/07/23 16:36
BTB-EC-X from 130-BF	T3D1085-26	Drinking Water	Grab		04/05/23 18:35	04/07/23 16:36
BTB-EC-West Gym-FL	T3D1085-27	Drinking Water	Grab		04/05/23 18:36	04/07/23 16:36
BTB-EC-West Gym-FR	T3D1085-28	Drinking Water	Grab		04/05/23 18:37	04/07/23 16:36
BTB-EC-Near 225-WD	T3D1085-29	Drinking Water	Grab		04/05/23 18:38	04/07/23 16:36
BTB-EC-West Gym-BF	T3D1085-30	Drinking Water	Grab		04/05/23 18:37	04/07/23 16:36
BTB-EC-By 230-FL	T3D1085-31	Drinking Water	Grab		04/05/23 18:40	04/07/23 16:36
BTB-EC-By 230-FR	T3D1085-32	Drinking Water	Grab		04/05/23 18:40	04/07/23 16:36
BTB-EC-By 230-BF	T3D1085-33	Drinking Water	Grab		04/05/23 18:41	04/07/23 16:36
BTB-EC-109C-SL	T3D1085-34	Drinking Water	Grab		04/05/23 18:47	04/07/23 16:36
BTB-EC-109C-SR	T3D1085-35	Drinking Water	Grab		04/05/23 18:47	04/07/23 16:36
BTB-EC-Near 516-FL	T3D1085-36	Drinking Water	Grab		04/05/23 17:44	04/07/23 16:36

BTB-EC-Near 516-FR	T3D1085-37	Drinking Water	Grab	04/05/23 17:44	04/07/23 16:36
BTB-EC-Near 516-BF	T3D1085-38	Drinking Water	Grab	04/05/23 17:45	04/07/23 16:36
BTB-EC-227-S	T3D1085-39	Drinking Water	Grab	04/05/23 18:45	04/07/23 16:36
BTB-EC-Hospitality-Ice	T3D1085-40	Drinking Water	Grab	04/05/23 18:45	04/07/23 16:36



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Analytical Testing Parameters

Client Sample ID: BTB-EC-Near 520-F

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-01

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:55

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1530	MMC

Client Sample ID: BTB-EC-101-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-02

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:01

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1535	MMC

Client Sample ID: BTB-EC-Stu.Kitch-Veggie Sink

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-03

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1537	MMC

Client Sample ID: BTB-EC-Stu.Kitch-35-5

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-04

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0049	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1539	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-Stu.Kitch-Ice

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-05

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1541	MMC

Client Sample ID: BTB-EC-Bistro-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-06

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1543	MMC

Client Sample ID: BTB-EC-Bistro-Ice

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-07

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1548	MMC

Client Sample ID: BTB-EC-535-3S-SL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-08

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1550	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-535-3S-SR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-09

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1552	MMC

Client Sample ID: BTB-EC-403-F

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-10

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1554	MMC

Client Sample ID: BTB-EC-403-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-11

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:16

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1556	MMC

Client Sample ID: BTB-EC-419-FL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-12

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:17

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1559	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-419-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-13

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1601	MMC

Client Sample ID: BTB-EC-419-FR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-14

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:18

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1603	MMC

Client Sample ID: BTB-EC-434-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-15

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1605	MMC

Client Sample ID: BTB-EC-405-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-16

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:20

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1610	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-306-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-17

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1612	MMC

Client Sample ID: BTB-EC-306-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-18

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:29

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1614	MMC

Client Sample ID: BTB-EC-Garden Cafe-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-19

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1616	MMC

Client Sample ID: BTB-EC-Garden Cafe-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-20

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/13/23 1307	04/13/23 1618	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-329-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-21

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:27

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1224	MMC

Client Sample ID: BTB-EC-Hall by 113-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-22

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:57

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1229	MMC

Client Sample ID: BTB-EC-Hall by 136-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-23

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1231	MMC

Client Sample ID: BTB-EC-X from 130-FL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-24

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:34

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1232	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-X from 130-FR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-25

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1234	MMC

Client Sample ID: BTB-EC-X from 130-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-26

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1235	MMC

Client Sample ID: BTB-EC-West Gym-FL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-27

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:36

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1240	MMC

Client Sample ID: BTB-EC-West Gym-FR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-28

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1242	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-Near 225-WD

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-29

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1243	MMC

Client Sample ID: BTB-EC-West Gym-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-30

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:37

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1245	MMC

Client Sample ID: BTB-EC-By 230-FL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-31

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1246	MMC

Client Sample ID: BTB-EC-By 230-FR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-32

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1249	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-By 230-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-33

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:41

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1251	MMC

Client Sample ID: BTB-EC-109C-SL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-34

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1253	MMC

Client Sample ID: BTB-EC-109C-SR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-35

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0134	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1254	MMC

Client Sample ID: BTB-EC-Near 516-FL

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-36

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1259	MMC



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Client Sample ID: BTB-EC-Near 516-FR

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-37

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1300	MMC

Client Sample ID: BTB-EC-Near 516-BF

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-38

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 17:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1302	MMC

Client Sample ID: BTB-EC-227-S

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-39

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1304	MMC

Client Sample ID: BTB-EC-Hospitality-Ice

Sample Matrix: Drinking Water

Lab Sample ID: T3D1085-40

Collected By: Lisa Knewasser

Collection Date: 04/05/2023 18:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.005 AL	0.0010	mg/L		04/14/23 1129	04/14/23 1305	MMC

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level
mg/L: Milligrams per Liter
RL: Reporting Limit



Microbac Laboratories, Inc., Pittston Division

CERTIFICATE OF ANALYSIS

T3D1085

Cooler Receipt Log

Cooler ID: Default Cooler

Temp: 16.1°C

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., Pittston Division
35-05082

Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

Joseph Palanza

Project Manager

Reported: 08/14/2023 10:08

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **16.1**

Therm ID **74**

Holding Time

Samples Received on Ice? ☒ Yes ☐ No ☐ N/A

Custody Seals Intact? ☒ Yes ☐ No ☐ N/A

Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Results Only ☐ Mail ☐ Fax ☐ e-mail (address) **SVangelal@bt-boces.org**

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address) **l.knewess@bt-boces.org**

PO No.: **607-752-0261 (cell)**

Location: **1.knewess@bt-boces.org**

Project: **1.knewess@bt-boces.org**

Sampler Signature: **1.knewess@bt-boces.org**

Sampler Phone No.: **607-752-0261 (cell)**

Sampled by (PRINT): **1.knewess@bt-boces.org**

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Thiosulfate, (8) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID

Client Sample ID

Date Collected

Time Collected

No. of Containers

Matrix

Grab / Comp

Preservative Types **

Sample Disposition

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)



Relinquished By (signature)



Broome-Tioga BOCES
PM: Kylie Ryan

Additional Notes

Lead Test



Dispose as appropriate ☐ Return ☐ Archive ☐

Received By (signature)

Date/Time **4/16/23 115**

Relinquished By (signature)

Date/Time **4/16/23 115**

Relinquished By (signature)

Date/Time **4/16/23 115**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

Received By (signature)

Date/Time **4-7-23**

Relinquished By (signature)

Date/Time **4/7/23**

Relinquished By (signature)

Date/Time **4/7/23**

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **14.1**
 Therm ID **7**
 Holding Time **Y**
 Samples Received on Ice? ☒ Yes ☐ No ☐ N/A
 Custody Seals Intact? ☒ Yes ☐ No ☒ N/A

Turnaround Time
☐ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

(needed by)

Report Type

Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address) **sva.gald@btbores.org**

Compliance Monitoring? ☐ Yes ☐ No
☐ Agency/Program


PO No.:

Sampler Phone No.:

Sampler Signature:

* Matrix Types: Soil/Solid (S), Sudge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS



Broome-Tioga BOCES
 PM: Kylie Ryan

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
11	BTB-EC-403-BF	4/15/23	6:10			X	HNO3	☒ Dispose as appropriate ☐ Return ☐ Archive	<i>Lisa Knewasser</i>	4/16/23 1:15	<i>[Signature]</i>	4/16/23 1:15
12	BTB-EC-419-FL		6:17									
13	BTB-EC-419-BF		6:18									
14	BTB-EC-419-FR		6:18									
15	BTB-EC-434-S		6:19									
16	BTB-EC-405-WD		6:20									
17	BTB-EC-306-S		6:29									
18	BTB-EC-306-WD		6:29									
19	BTB-EC-Garden Life-S		6:32									
20	BTB-EC-Garden Life-WD		6:24									

Possible Hazard Identification
☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Relinquished By (signature)

Date/Time

1:15

Received By (signature)

Date/Time

4/16/23 1:15

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

4/17/23 12:57

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

4/17/23 16:36

Melvin Payeth

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **16.1**

Therm ID **7y**

Holding Time

Samples Received on Ice? ☒ Yes ☐ No ☐ N/A

Custody Seals Intact? ☒ Yes ☐ No ☒ N/A

Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Results Only ☐ Mail ☐ Fax ☒ e-mail (address) **svan.gald@btbores.org**

Compliance Monitoring? ☐ Yes ☐ No

Agency/Program

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Additional Notes

Lead test

Broome-Tioga BOCES

PM: Kylie Ryan

Sample Disposition

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Lab Report Address **435 Glenwood Rd**

Client Name: **BT BOCES**

Address: **435 Glenwood Rd**

City, State, Zip: **Binghamton, N.Y. 13905**

Contact: **Lisa Kneewasser**

Telephone No.: **607-752-0261 (cell)**

Send Report via: ☒ Mail ☐ Fax ☐ e-mail (address) **Lkneewass@btbores.org**

Location:

Invoice Address **Same**

Client Name:

Address:

City, State, Zip:

Contact: **Sara Van Galder**

Telephone No.: **607-763-3354**

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address) **svan.gald@btbores.org**

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix

Preservative Types **

No. of Containers

Time Collected

Date Collected

Client Sample ID

Lab ID

21 BTB-EC-324-S

22 BTB-EC-14113-WD

23 BTB-EC-136-S

24 BTB-EC-X from 130-FL

25 BTB-EC-X from 130-FL

26 BTB-EC-X from 130-BF

27 BTB-EC-West Gym-FL

28 BTB-EC-West Gym-BF

29 BTB-EC-Wear 225-WD

30 BTB-EC-West Gym-BF

Possible Hazard Identification

Comments

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via:

Location:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via:

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix

Preservative Types **

No. of Containers

Time Collected

Date Collected

Client Sample ID

Lab ID

21 BTB-EC-324-S

22 BTB-EC-14113-WD

23 BTB-EC-136-S

24 BTB-EC-X from 130-FL

25 BTB-EC-X from 130-FL

26 BTB-EC-X from 130-BF

27 BTB-EC-West Gym-FL

28 BTB-EC-West Gym-BF

29 BTB-EC-Wear 225-WD

30 BTB-EC-West Gym-BF

Possible Hazard Identification

Comments

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via:

Location:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via:

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix

Preservative Types **

No. of Containers

Time Collected

Date Collected

Client Sample ID

Lab ID

21 BTB-EC-324-S

22 BTB-EC-14113-WD

23 BTB-EC-136-S

24 BTB-EC-X from 130-FL

25 BTB-EC-X from 130-FL

26 BTB-EC-X from 130-BF

27 BTB-EC-West Gym-FL

28 BTB-EC-West Gym-BF

29 BTB-EC-Wear 225-WD

30 BTB-EC-West Gym-BF

Possible Hazard Identification

Comments

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via:

Location:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via:

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix

Preservative Types **

No. of Containers

Time Collected

Date Collected

Client Sample ID

Lab ID

21 BTB-EC-324-S

22 BTB-EC-14113-WD

23 BTB-EC-136-S

24 BTB-EC-X from 130-FL

25 BTB-EC-X from 130-FL

26 BTB-EC-X from 130-BF

27 BTB-EC-West Gym-FL

28 BTB-EC-West Gym-BF

29 BTB-EC-Wear 225-WD

30 BTB-EC-West Gym-BF

Possible Hazard Identification

Comments

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via:

Location:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via:

PO No.:

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

Matrix

Preservative Types **

No. of Containers

Time Collected

Date Collected

Client Sample ID

Lab ID

21 BTB-EC-324-S

22 BTB-EC-14113-WD

23 BTB-EC-136-S

24 BTB-EC-X from 130-FL

25 BTB-EC-X from 130-FL

26 BTB-EC-X from 130-BF

27 BTB-EC-West Gym-FL

28 BTB-EC-West Gym-BF

29 BTB-EC-Wear 225-WD

30 BTB-EC-West Gym-BF

Possible Hazard Identification

Comments

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Lab Report Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via:

Location:

Invoice Address

Client Name:

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Invoice via:

PO No.:

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **16.1**
 Therm ID **7**
 Holding Time **Y**
 Samples Received on Ice? ☒ Yes ☐ No ☐ N/A
 Custody Seals Intact? ☒ Yes ☐ No ☒ N/A

Turnaround Time
☐ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

Invoice Address **Same**

Client Name:

Address:

City, State, Zip:

Contact: **Sara Van Gelder**

Telephone No.: **607-763-3354**

Send Report via: ☒ Mail ☐ Fax ☐ e-mail (address) **L.knewass@btboces.org**

Location:

PO No.:

Compliance Monitoring? ☐ Yes ☐ No
☐ Agency/Program

Sampler Phone No.:

Sampler Signature:

Sampled by (PRINT):

* Matrix Types: Soil/Solid (S), Sudge, Oil, Wipe, Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS



Broome-Tioga BOCES
 PM: Kylie Ryan

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
31	BTB-EC-by 230-FL	4/15/23	6:40		X	X	HNO3	Lead Testing
32	BTB-EC-by 230-FR		6:40					
33	BTB-EC-by 230-BF		6:41					
34	BTB-EC-109C-SL		6:47					
35	BTB-EC-109C-SR		6:47					
36	BTB-EC-near 516-FL		5:44					
37	BTB-EC-near 516-FR		5:44					
38	BTB-EC-near 516-BF		5:45					
39	BTB-EC-227-S		6:45					
40	BTB-EC-Hospitality-ice							

Possible Hazard Identification
☒ Hazardous ☐ Non-Hazardous ☐ Radioactive

Sample Disposition
☒ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)
Lisa Knewass

Date/Time
4/15/23 1:15

Received By (signature)
[Signature]

Date/Time
4-7-23 12:01

Relinquished By (signature)
[Signature]

Date/Time
4/7/23

Received By (signature)
[Signature]

Date/Time
4/7/23 16:30

Relinquished By (signature)
[Signature]

Date/Time
4/7/23

Received By (signature)
[Signature]

Date/Time
4/7/23 16:30