

Leslie F. Distin Educational Center - 435 Glenwood Road, Binghamton, NY 13905

Lead in Drinking Water testing – First Draw - 2020

Room #	Fixture	Sample Type	Test Date	EPA Limit is 0.0150	Test result
1 <sup>st</sup> FL MRR	Sink R	First Draw	11/25/2020		0.0013
1 <sup>st</sup> FL MRR	Sink L	First Draw	11/25/2020		0.0011
1 <sup>st</sup> FL WRR	Sink – L	First Draw	11/25/2020		0.0010
1 <sup>st</sup> FL WRR	Sink – R	First Draw	11/25/2020		<0.0010
101 Cosmo	RR Sink		10/20/2020		<0.0010
101 Cosmo mix rm	Sink - L		10/20/2020		0.0019
101 Cosmo mix rm	Sink - R		10/20/2020		0.0011
103 Health Office	RR Sink -1		10/20/2020		<0.0010
103 Health Office	RR Sink		11/25/2020		0.0010
103 Health Office	Sink		10/20/2020		0.0047
105 Nursing Lab	Sink – L		10/20/2020		<0.0010
105 Nursing Lab	Sink – R		10/20/2020		<0.0010
107 Cosmo	RR Sink -2		10/20/2020		<0.0010
108 Nursing Lab	Sink – L		10/20/2020		<0.0010
108 Nursing Lab	Sink – R		10/20/2020		<0.0010
111 Office Area	Sink		10/20/2020		0.0019
112 Area RR	RR Sink 1		10/20/2020		0.0024
112 Area RR	RR Sink 2		10/20/2020		0.0015
112 Area RR	RR Sink 3		10/20/2020		<0.0010
112 B – PALS classroom	Sink		10/20/2020		0.0024
112 Hall area – Girls Rm	RR Sink – L		11/25/2020		<0.0010
112 Hall area – “110” Girls	RR Sink - R		11/25/2020		0.0011
112 Kitchen area	Sink		10/20/2020		0.0017
112 Oak Tree	Sink-L		10/20/2020		0.0017
112 Oak Tree	Sink-R		10/20/2020		0.0010
112 Oak Tree	RR Sink		10/20/2020		0.0021
115	Sink		11/25/2020		<0.0010
117	Sink		11/25/2020		<0.0010
118	Sink		10/20/2020		0.0014
119	Sink		10/20/2020		<0.0010
136 – P-Tech	Sink		11/25/2020		0.0128
224 Evertech Art	Sink		10/20/2020		<0.0010
225 Evertech Science	Sink		10/20/2020		<0.0010
2 <sup>nd</sup> FL Boys Rm	RR Sink -1		11/25/2020		0.0026
2 <sup>nd</sup> FL Boys Rm	RR Sink -2		11/25/2020		0.0031
2 <sup>nd</sup> FL Boys Rm	Rr Sink -3		11/25/2020		0.0029
2 <sup>nd</sup> FL Boys Rm	RR Sink -4		11/25/2020		0.0023
2 <sup>nd</sup> FL Girls Rm	RR Sink -1		11/25/2020		0.0027
2 <sup>nd</sup> FL Girls Rm	RR Sink -2		11/25/2020		0.0034
2 <sup>nd</sup> FL Girls Rm	RR Sink -3		11/25/2020		0.0030
2 <sup>nd</sup> FL Girls Rm	RR Sink -4		11/25/2020		0.0025

Room #	Fixture	Sample Type	Test Date	EPA Limit is 0.0150	Test result
2 <sup>nd</sup> FL Staff RR	RR Sink L		11/25/2020		0.0021
2 <sup>nd</sup> FL Staff RR	RR Sink L		11/25/2020		0.0026
2 <sup>nd</sup> FL Staff RR between 215-217	RR Sink		11/25/2020		0.0030
300 Wing Mens Rm	Sink L		11/25/2020		0.0018
300 Wing Mens Rm	Sink R		11/25/2020		0.0030
300 Wing Womens Rm	Sink L		11/25/2020		0.0015
300 Wing Womens Rm	Sink R		11/25/2020		0.0012
303	Sink		11/25/2020		<0.0010
303	RR Sink		10/20/2020		0.0013
304	Sink		11/25/2020		0.0010
304	RR Sink		10/20/2020		0.0020
305	Sink		11/25/2020		0.0021
307	Sink		11/25/2020		0.0043
308	Sink		11/25/2020		0.0053
309	Sink		11/25/2020		0.0059
309	Sink		10/20/2020		<b>0.0197</b>
309 (retest)	Sink	Replaced faucet & retested	1/25/2021		0.0067
310	Sink		11/25/2020		0.0016
312	RR Sink		10/20/2020		0.0105
313 Changing room	Sink		10/20/2020		0.0022
316	Sink		11/25/2020		0.0053
316	RR Sink		10/20/2020		0.0024
317	Sink		11/25/2020		0.0043
317	RR Sink		10/20/2020		0.0071
318	Sink		11/25/2020		0.0043
322	Sink		10/20/2020		0.0029
323 Maintenance & RR	Sink		10/20/2020		0.0048
326	Sink		11/25/2020		0.0016
329	Sink		11/25/2020		<0.0010
329 connects with 330	Sink		10/20/2020		0.0080
331	RR Sink		10/20/2020		0.0031
331	Sink		10/20/2020		0.0017
332	RR Sink		10/20/2020		0.0038
333	RR Sink		10/20/2020		0.0031
400 Main Hall Mens Rm	RR Sink L		11/25/2020		<0.0010
400 Main Hall Mens Rm	RR Sink R		11/25/2020		<0.0010
400 Main Hall Womens Rm	RR Sink L		11/25/2020		<0.0010
400 Main Hall Womens Rm	RR Sink R		11/25/2020		<0.0010
400 Wing Oak Tree Mens Rm	RR Sink – L		11/25/2020		<0.0010

Room #	Fixture	Sample Type	Test Date	EPA Limit is 0.0150	Test result
400 Wing Oak Tree Women's Rm	RR Sink – R		11/25/2020		<0.0010
400 Wing Oak Tree Women's Rm	RR Sink – L		11/25/2020		<0.0010
400 Wing Oak Tree Women's Rm	RR Sink – R		11/25/2020		<0.0010
405 Kitchen area	Water dist		10/20/2020		<0.0010
405 Office Area (Mullins)	Kitchen Sink		10/20/2020		0.0014
430 Laundry	Sink		10/20/2020		<0.0010
431 Garden/Plant area	Sink		10/20/2020		<0.0010
434 Oak Tree Kitchen	Kitchen Sink		10/20/2020		<0.0010
506A Office Suite	Kitchen Sink		10/20/2020		<0.0010
506	Sink L		11/25/2020		0.0013
506	Sink R		11/25/2020		0.0015
511 IT Specialist	RR Sink		10/20/2020		0.0011
513 Maker Space	Sink		10/20/2020		<0.0010
535 Hospitality	Sink 1		10/20/2020		0.0012
535 Hospitality	Sink 2		10/20/2020		0.0018
535 Hospitality	Sink 3		10/20/2020		<0.0010
AS SUNY Fast Forward Room	Sink – L		10/20/2020		0.0047
AS SUNY Fast Forward Room	Sink – M		10/20/2020		0.0023
AS SUNY Fast Forward Room	Sink – R		10/20/2020		0.0011
Bistro Kitchen	Sink 1 DS-LS		10/20/2020		<0.0010
Bistro Kitchen	Sink 2 DS-RS		10/20/2020		<0.0010
Bistro Kitchen	Sink 3DW – S		10/20/2020		<0.0010
Bistro Kitchen	Sink 4 – 2 <sup>nd</sup> DWW		10/20/2020		<0.0010
Bistro Kitchen	Sink 5 -HWS		10/20/2020		0.0038
Bistro Kitchen	Sink 6 – 2 <sup>nd</sup> double		10/21/2020		<0.0010
Bistro Kitchen	Sink 7 – 2 <sup>nd</sup> HW		10/21/2020		0.0010
Bistro Kitchen	Sink 8 – 3 <sup>rd</sup> dbl		10/21/2020		<0.0010
Bistro Kitchen	Ice Machine		10/20/2020		<0.0010
Café Kitchen Island	Sink		10/21/2020		0.0047
Café Kitchen Island	Sink – 3 bay		10/21/2020		0.0024
Café Kitchen RR	RR Sink		10/21/2020		0.0015

Room #	Fixture	Sample Type	Test Date	EPA Limit is 0.0150	Test result
Ed Ctr Cafe	Sink 1		10/20/2020		0.0017
Ed Ctr Cafe	Sink 2		10/20/2020		<0.0010
Ed Ctr Cafe	Sink 3		10/20/2020		<0.0010
Ed Ctr Cafe	Sink 4		10/20/2020		0.0033
Garden Café – 325 (room behind GC)	Sink		10/20/2020		<0.0051
Girls Rm net to Visions	RR Sink		11/25/2022		0.0082
Gym Office RR	RR Sink		10/21/2020		0.0042
Hall to Lg Gym – Mens Rm	RR Sink		11/25/2020		0.0025
Hall to Lg Gym Womens Rm	RR Sink		11/25/2020		0.0023
Hall Womens RR by 508A	RR Sink		11/25/2022		<0.0010
Hall Womens RR by 516	RR Sink		11/25/2022		<0.0010
Hall Womens RR by 525	RR Sink		11/25/2022		<0.0010
Hall Womens RR by 533-L	RR Sink		11/25/2022		<0.0010
Hall Womens RR by 533-R	RR Sink		11/25/2022		<0.0010
Mens Rm Lg Gym SL- RR	RR Sink – 1		11/25/2020		0.0060
Mens Rm Lg Gym SL- RR	RR Sink – 2		11/25/2020		0.0047
Mens Rm Lg Gym SL- RR	RR Sink - 3		11/25/2020		0.0051
Mens Rm Lg Gym SL- RR	RR Sink – 4		11/25/2020		0.0048
Mens Rm Lg Gym SL- RR	RR Sink - 5		11/25/2020		0.0033
Nurses Office	Sink		10/20/2020		0.0092
Suction space by room 330 just sink	Sink		10/20/2020		0.0048
Water Dispenser – Garden Café	WD		10/20/2020		<0.0010
Water Dispenser O&M Kitchen area	WD		10/20/2020		<0.0010
Water Dispenser – 2 <sup>nd</sup> Floor	WD		10/20/2020		<0.0010
Water Dispenser by 113	WD		10/20/2020		<0.0010
Water Dispenser by 503b	WD		10/20/2020		<0.0010
Water Dispenser by 516	WD		10/20/2020		<0.0010
Water Dispenser by main hall	WD		10/20/2020		<0.0010
Water Dispenser Receiving	WD		10/20/2020		<0.0010
Womens Rm Lg Gym SL- RR	RR Sink – 1		11/25/2020		0.0042
Womens Rm Lg Gym SL- RR	RR Sink – 2		11/25/2020		0.0049
Womens Rm Lg Gym SL- RR	RR Sink - 3		11/25/2020		0.0037

	Room #	Fixture	Sample Type	Test Date	EPA Limit is 0.0150	Test result
	Womens Rm Lg Gym SL-RR	RR Sink - 4		11/25/2020		0.0030
	Womens Rm Lg Gym SL-RR	RR Sink - 5		11/25/2020		0.0028