

West Learning Center – 471 Pennsylvania Avenue, Apalachin, New York 13732

Lead in Drinking Water testing

	Room #	Fixture	Sample Type First Draw	Test Date	EPA limit is 0.0150	Test result
	100 Wing Staff RR -	RR Sink – L		11/25/2020		0.0071
	100 Wing Staff RR -	RR Sink – R		11/25/2020		0.0025
	100 Wing Handicapped RR -	RR Sink – R		11/25/2020		0.0083
	100 Wing Handicapped RR	RR Sink – L		11/25/2020		0.0138
	100 Wing RR x from gym	RR Sink		11/25/2020		0.0041
	100 Wing RR x from gym	RR Sink		11/25/2020		0.0045
	100 wing staff Lounge	Sink		11/25/2020		0.0047
	100 wing staff RR x from gym	RR Sink – L		11/25/2020		0.0138
	108	Sink		11/25/2020		0.0052
	200 Wing Men’s room	RR Sink		11/25/2020		0.0117
	200 Wing Women’s room	RR Sink		11/25/2020		0.0017
	200 Wing Women’s room	RR Sink		11/25/2020		0.0057
	202	Sink				
	302	RR Sink		11/25/2020		0.0080
	304	RR Sink		11/25/2020		0.0046
	304	Sink		11/25/2020		0.0061
	306	RR Sink		11/25/2020		0.0046
	306	Sink		11/25/2020		0.0043
	308	RR Sink		11/25/2020		<b>0.0211</b>
	308	RR Sink	Replaced faucet and re-tested	1/14/2021		0.0034
	308	Sink		11/25/2020		0.0042
	319-nurse	RR Sink		11/25/2020		0.0115
	310	RR Sink		11/25/2020		0.0062
	310	Sink		11/25/2020		0.0018
	312	Sink		11/25/2020		0.0120
	312	RR Sink		11/25/2020		0.0110
	314	RR Sink		11/25/2020		0.0047
	314	Sink		11/25/2020		0.0028

	Room #	Fixture	Sample Type First Draw	Test Date	EPA limit is 0.0150	Test result
	316	Sink		11/25/2020		0.0101
	316	RR Sink		11/25/2020		0.0061
	400 wing – common area	Sink		11/25/2020		<b>0.0319</b>
	400 Wing common area	Sink	Replaced faucet and re-tested	1/14/2021		0.0055
	402	RR Sink		11/25/2020		0.0141
	402	Sink		11/25/2020		0.0035
	404	RR Sink		11/25/2020		0.0049
	404	Sink		11/25/2020		0.0102
	Main Office	RR Sink		11/25/2020		0.0076